

Housekeeping and Storage

- ❑ Garbage disposal bins are 10 feet (3 metres) from combustible buildings and openings.
- ❑ For oily rags and similar materials subject to spontaneous combustion, must have an approved metal container with a close fitting, self-closing, and metal cover provided.
- ❑ In unsprinklered buildings, a clearance of not less than one metre between the top of storage and the underside of the floor or roof deck must be maintained.
- ❑ Boiler, mechanical, and electrical rooms are free of storage.
- ❑ Combustible waste materials in and around the building shall not be permitted to accumulate in quantities or locations that will constitute a fire hazard.
- ❑ All compressed gas cylinders are to be secured in an upright position to keep them from falling over.

High-Rack Storage

- ❑ Commodities stored on rack shelving must comply with height regulations in the current BC Fire Code. It is the responsibility of the applicant to ensure sprinkler coverage complies with the base building fire sprinkler design and consultation with a fire protection engineer may be required.
- ❑ Owners Information Certificate may be required for the intended commodities storage.



If you have any questions contact:

Township of Langley Fire Department
22170 – 50 Avenue, Langley, BC V2Y 2V4
604-532-7500 | fireinfo@tol.ca

Business Licence Fire Inspections



The Township of Langley Fire Department is dedicated to improving the overall safety of businesses within our community. Every business in our community is required to operate with a valid business licence in accordance with Township of Langley bylaws, the BC Fire Code, and the Fire Services Act.

The fire department will contact you to schedule an inspection. Please allow 2 to 3 weeks from initial business licence application. Read this brochure prior to your inspection.



Inspection

The purpose of the inspection is to ensure your business meets the life safety standards to protect your customers, employees, and yourself from the harmful effects of fire. Compliance also protects your property and equipment investment.

Businesses with a change of owner who do not require a Tenant Improvement Permit or businesses moving into an existing occupied floor area with no change to occupancy type (such as a new doctor's office in an existing doctor's office, hair or nail salon, or shared office space) may continue to operate as usual prior to our inspection.

All fire and life safety protection systems are in an operable condition and have been serviced within the last year.

The following is a checklist of some basic safety items we will be inspecting. Your cooperation in dealing with these items prior to our inspection will assist in processing your business licence application.

Address

- ❑ Address numbers are the required size and are clearly visible and legible from the street or road fronting the property as per Fire Prevention Bylaw No. 6061.

Unit Numbers

- ❑ Unit numbers to be posted on the front and rear doors in such a manner as to be easily visible from a distance.

Access for Firefighting and Emergency Access Routes

- ❑ Fire lanes are clearly marked, unobstructed, and maintained.

Fire Hydrants and Fire Department Connections

- ❑ Access to fire hydrants, fire department connections, and other fire protection equipment is not obstructed.
- ❑ A 3 feet (1 metre) clear space is maintained around the hydrants and fire department connections.

Fire Extinguishers

- ❑ A minimum of one 2A BC10 fire extinguisher mounted on the wall and available within 50 feet (15 metres) of walking distance from any location within the occupancy, and on each level. This may vary depending on your occupancy.
- ❑ All fire extinguishers are in operable condition and have been serviced and tagged within the last year.
- ❑ One K-class fire extinguisher is provided within 30 feet (10 metres) of commercial cooking equipment if there is a kitchen suppression system.

Smoking

- ❑ Designated safe smoking areas are to be provided.

Exits and Exit Doors

- ❑ Access to exits, aisles, and corridors are not obstructed in any way.

- ❑ Emergency lights are installed, functioning properly, and have been serviced and tagged in the last year.
- ❑ Exit doors are operable from the inside without the use of a key or any special knowledge (such as not locked, chained, bolted, barred, or otherwise rendered unusable when the building is occupied).
- ❑ Exit signs and exit lighting shall be illuminated when the building is occupied.

Extension Cords

- ❑ Only utilized for temporary occasions and must not be used in series.
- ❑ Except for approved multi-plugged cords, extension cords must only serve one portable appliance/device at a time.
- ❑ Must not be affixed to structures, do not extend through walls, ceilings, floors, or under doors or floors coverings, or are subject to environmental or physical damage.

Fire Protection Systems

- ❑ All fire protection systems and appliances are in an operative condition.
- ❑ Access to and clearance around the fire sprinkler riser is maintained.
- ❑ The automatic fire sprinkler and fire alarm systems have been serviced within the last year, and a tag documenting that service is affixed to the riser.
- ❑ The kitchen hood fire extinguishing system has been serviced and cleaned in the last six months, and a tag documenting that service has been attached to the manual activation handle.